



REVISION BLOCK			
REV	DESCRIPTION	DATE	INCORP. BY

NOTES:

Glycol flow controlled by Actuator Voltage. 0V is Closed; 10V is Open.

Pressure error – Mc.pressure error is TRUE (cooler is frozen).

TM_avg = Average of IQUP's TM1, TM2, TM3, TM4, TM5, TM6.. Deg C

DewPt1 = IQUP Dew Point sensor in mirror cell.

HM = Humidity of Mirror Cell, calculated using TM_avg and DewPt1.

DWG #	REV	TITLE	
T3-3152	-	Mirror Cooling Logic	
ENGINEER	LAST EDIT	SIZE	SHEET
T. Denault	3/11/2010 2:09:09 PM	B	1 of 1
FILE: Y:\public_html\tcs3\Design\T3-3152-Mirror_Cooling_Logic.vsd			