

C SIZE FINAL TEST
ZD22H420-EL
H1101180011
H0710/0120
FT7

Power Base ID = 1011 - 0001 - 0001
STD CT STD VT QT CT QT VT PRESENT
CONT CUR. = 27.0 27.0 21.0 27.0 27.0 A RMS
PEAK CUR. = 50.0 31.5 46.0 31.0 50.0 A RMS
RATED PWM = 2.5 2.5 8.0 8.0 2.5 kHz
Current Scaling = 11.00 A/V
DC Bus Voltage = 756 V
Controller Temp = 27.1 C
SOFTWARE = S18-3.24

1822 RPM
61.9 Hz
460 V RMS
49.6 A RMS
0:00:27 Present Run Time

1822 RPM
61.9 Hz
460 V RMS
49.4 A RMS
0:10:08 Present Run Time

1822 RPM
61.9 Hz
459 V RMS
49.5 A RMS
0:20:38 Present Run Time

C SIZE FINAL TEST
ZD22H420-EL
H1101280047
H1210/0377
FT7

Power Base ID = 1011 - 0001 - 0001
STD CT STD VT QT CT QT VT PRESENT
CONT CUR. = 27.0 27.0 21.0 27.0 27.0 A RMS
PEAK CUR. = 50.0 31.5 46.0 31.0 50.0 A RMS
RATED PWM = 2.5 2.5 8.0 8.0 2.5 kHz
Current Scaling = 11.00 A/V
DC Bus Voltage = 747 V
Controller Temp = 26.6 C
SOFTWARE = S18-3.24

1820 RPM
61.8 Hz
460 V RMS
49.8 A RMS
0:00:31 Present Run Time

1820 RPM
61.8 Hz
460 V RMS
49.9 A RMS
0:10:39 Present Run Time

1820 RPM
61.8 Hz
459 V RMS
49.9 A RMS
0:20:24 Present Run Time